



## HYDROGEOLOGIC DATABASE Chemical Analysis

### Sample Results Color Code Legend

Sample Exceeds [ None  
Secondary  
Primary ] **MCL**



[Click HERE to View Information for Well HPB](#)

Owner Name: **Finisterre Heights Wellfield**

Well Key: **HPB** Site Type: **Wellfield**

TRS:

PWS Name: **Finisterre Heights Water System**

DOH PwsID: **02145** DOH Source #: **3**

Source	Date	Bicarbonate			Conductivity			Hardness			Turbidity				
		Alk	As	Ca	Cl	Fe	K	Mg	Mn	Na	NO3	SO4	TDS		
DOH	9/11/2018		0.0019		21.5	416					< 0.01		3.8	< 50	3
DOH	9/11/2018			31.8			0.463	168		21.5		15.8			
DOH	8/28/2019												2.44		
DOH	9/1/2020												4.34		

### Select Summary Statistics

Avg As:	0.002	Avg Cl:	21.5	Avg Hardness:	168	Avg NO3:	3.53
Median As:	0.0019	Median Cl:	21.5	Median Hardness:	168	Median NO3:	3.8
Max As:	0.0019	Max Cl:	21.5	Max Hardness:	168	Max NO3:	4.34

Bacteria Samples (distribution): [330 sample\(s\)](#)

Disclaimer: Data presented has been collected from a variety of sources. Island County makes no guarantee as to the validity or accuracy of this data. Please report any errors to the Island County Hydrogeologist.

Generated by the Island County Hydrogeologic Database

4 records printed on 9/29/2020

Note: Items with [blue frames and blue text](#) are clickable hyperlinks to additional information / resources.

Parameter labels with a [red fill color](#) are exhibiting an increasing trend, and those with a [green fill color](#) are exhibiting a decreasing trend.